

Public Health Laboratory

3rd Floor, Ambedkar Shopping Centre, Nr. Mandarwaja Fire Station, Ring Road Surat - 2 Phone No. (0261) 23,37421

Name And Address of Party .	Alchemy School, Canal Road, Ladvi Gam, Kamrej, Surat	Report No.PHL/WC/831/2020-2021	
		Date of Receipt of Sample	04/02/2021
Type of Sample:-	Private	Jampie	
Source of the Water:-	R.O.Water		

Water Sample Test Report

Sr. No.	Quality Characteristic Test	Result	Prescribed Standards a per IS 10500:2012 Max. 1 NTU.	
1.	Turbidity	Clear		
2.	Taste	Agreeable	Agreeable.	
3.	Free Residual Chlorine	Absent	Max. 0.2mg/lit.	
4.	Odour	Agreeable	Agreeable.	
5.	pH Value	6.8	6.5 To 8.5.	
3 .	Ammonia (as Total Ammonia-N)	Absent	Max. 0.5mg/lit.	
7. Nitrate (as NO₃)		Absent	Max. 45mg/lit.	
Chlorides (as Cl)		10.0	Max. 250mg/lit	
9.	Total Alkalinity (as Calcium Carbonate)	10.0	Max. 200mg/lit	
10.	Total Hardness (as CaCo ₃)	05.0	Max. 200mg/lit	
1.	Total Dissolved Solids	25.0	Max. 500mg/lit	

Opinion: - The Sample is FIT for drinking Purpose, With Respect to the Tests Performed above.

Date: - 18-02-202

Note:-

ALCHEMY SCHOOL LADVI, DIST SURAT

Food Analyst **Surat Municipal Corporation**

Surator ALCHEMY SCHOOL

Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.

❖ Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.

11263/64 No. D.P./H.S./School/Alchemy school -Ladvi/17 District Panchayat (Health), SURAT. Dt. 25/9/2017

To,

The Chief Executive
Central Education Board,
Delhi.

Subject: Opinion regarding the Health....

Ref. : Application of Principal, Alchemy school , At & Po. Ladvi, --Ta.Kamrej, Dist. Surat, Dt. 27/6/2017 & letter dated 14/9/2017

With reference to the subject noted above, it is stated that The Alchemy School situated at village Ladvi, Ta.Kamrej, Dist.Surat has asked for issuing health and sanitation certificate for the school. We have no objection for the same, full filling following conditions;

- 1. Safe/Chlorinated drinking water must be provided permanently.
- 2. Latrine, bathrooms, urinals etc; are cleaned daily with effective disinfectant.
- 3. School and its surrounding area kept cleaned permanently.
- 4. A first-aid box must be available in the school permanently.

Copy Forwarded:

Principal,
Alchemy school,
At & Post - Ladvi,
Ta. Kamrej,
Dist. Surat .
-/ For Information

Chief District Health Officer District Panchayat, Surat.

PRINCIPAL
ALCHEMY SCHOOL
LADVI, DIST SURAT

FOR ALCHEMY SCHOOL

DIRECTOR